



QPS Evaluation Services Inc
Testing, Certification and Field Evaluation Body
Accredited in Canada, the USA, and Internationally

File
LR1504

CERTIFICATE OF COMPLIANCE
(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	Solexy Srl	
Address	Via Enrico Fermi 2 I-25015 Desenzano del Garda (BS) Italy	
Project Number	LR1504-1	
Product	Instrument Enclosure	
Model Number	WA and WS Series <ul style="list-style-type: none"> o HWA/HWS – Enclosure complete with terminals only o SWA/SWS – Enclosure complete with electronic devices 	
Ratings	Type 1, 4 and 4X Enclosure	
Conditions of Acceptability	See Annex A	
Markings	<p><u>HWA/HWS:</u> Class I, Division 1, Groups B, C and D T4 Class II, Division 1, Groups E, F and G T4 Class I, Zone 1, Groups IIB+H₂ [For U.S only] Zone 21, Groups IIIC [For U.S only]</p> <p><u>SWA/SWS:</u> Class I, Division 1, Groups B, C and D Class II, Division 1, Groups E, F and G Class I, Zone 1, Groups IIB+H₂ [For U.S only] Zone 21, Groups IIIC [For U.S only]</p>	
Applicable Standards	CSA C22.2 No. 94.2-15 UL 50E, Edition 2.0 CSA C22.2 No. 30-M1986	UL 1203, Edition 5.0 CSA C22.2 No. 25-17
Factory/Manufacturing Location	Same as Applicant	

Statement of Compliance: The product(s) identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be in compliance with the relevant requirements of the above referenced standard(s). As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.



Issued By: Dave Adams, P. Eng.
 Manager, Hazardous Locations [Ex Equipment] Department

Signature:

Date: December 11, 2019



QPS Evaluation Services Inc
Testing, Certification and Field Evaluation Body
Accredited in Canada, the USA, and Internationally

File
LR1504

Annex A:

Conditions of Acceptability:

HWA/HWS:

- Only XCIB2/8 and/or XCFR2/8 recognized terminal blocks and RF connectors may be installed within the enclosure
- The terminal blocks shall be used and installed per the conditions of use stated by the their individual component certificates
- The spacings of the terminal blocks and RF connectors shall be in accordance with the spacing requirements of UL 508 and CSA 14
- Routine dielectric strength test shall be applied to 100% of manufactured samples before labelling.

SWA/SWS:

- The SWA/SWS devices shall only be supplied by a Class 2 source or a Limited Power Source

Notes:

1. These devices consist of RF wireless devices; the manufacturer is responsible for compliance with FCC and Industry Canada Regulations.